



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
JCR20	8.0	Upright	QR	Job F3 3mm	3/4	Brass, Chrome	155, 175, 286 (68, 79, 141)

Prepared for: SKOP Indústria e Comércio de Aparelhos contra Incêndio
Rua Braga 57, Penha Circular, Rio de Janeiro 21011-500
Brazil

Manufacturing Location: SKOP Indústria e Comércio de Aparelhos contra Incêndio
Rua Braga 57, Penha Circular, Rio de Janeiro 21011-500
Brazil

FM Approvals Class: 2001
FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR462819

Approval Granted: 23 January 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

